COF fly ash

# COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • TEL: 630-953-9300 FAX: 630-953-9306

SINCE 1908®

SGS Member of the SGS Group (Société Générale de Surveillance)

ADDRESS ALL CORRESPONDENCE TO:
4665 PARIS STREET
SUITE B-200
DENVER, CO 80239
TEL: (303) 373-4772
FAX: (303) 373-4791
www.comteco.com

May 30, 2002

TENNESSEE VALLEY AUTHORITY
1101 Market Street PSC 1A
Chattanooga TN 37402
RENEE B. MERRELL

SAMPLE No.: 257741
SAMPLE TYPE: DRY FLY ASH
REMARKS: FLY

**Date Received** March 5, 2002
**Analysis report no.** 72-470138

**PROXIMATE ANALYSIS**

| | As Received | Dry Basis |
|---|---|---|
| % Moisture | 0.19 | xxxxxx |
| % Ash | 93.27 | 93.45 |
| % Volatile | < 0.01 | < 0.01 |
| % Fixed Carbon | 6.53 | 6.54 |
| | 100.00 | 100.00 |
| Btu/lb | 706 | 707 |
| % Sulfur | 0.36 | 0.36 |
| MAF Btu/lb | 10794 | |

**ULTIMATE ANALYSIS**

| | As Received | Dry Basis |
|---|---|---|
| % Moisture | 0.19 | xxxxxx |
| % Carbon | 5.70 | 5.71 |
| % Hydrogen | 0.13 | 0.13 |
| % Nitrogen | 0.36 | 0.36 |
| % Sulfur | 0.36 | 0.36 |
| % Ash | 93.27 | 93.45 |
| % Oxygen | xxxxxx | xxxxxx |
| | 100.00 | 100.00 |

**ANALYSIS OF ASH** — % Weight Ignited Basis

| | |
|---|---|
| Silica, $SiO_2$ | 56.22 |
| Alumina, $Al_2O_3$ | 23.85 |
| Titania, $TiO_2$ | 1.01 |
| Ferric Oxide, $Fe_2O_3$ | 9.92 |
| Lime, CaO | 4.04 |
| Magnesia, MgO | 1.15 |
| Potassium Oxide, $K_2O$ | 1.75 |
| Sodium Oxide, $Na_2O$ | 0.54 |
| Sulfur Trioxide, $SO_3$ | 0.66 |
| Phosphorous Pentoxide, $P_2O_5$ | 0.44 |
| Strontium Oxide, SrO | 0.11 |
| Barium Oxide, BaO | 0.25 |
| Manganese Oxide, $Mn_3O_4$ | 0.06 |
| Undetermined | 0.00 |
| Alks. as $Na_2O$, Dry Coal Basis | 1.58 |
| Base:Acid Ratio | 0.21 |
| T250 Temperature | 2707 |

| | |
|---|---|
| Silica Value | 78.82 |
| Type of Ash | BITUMINOUS |
| Fouling Index | 0.11 |
| Slagging Index | 0.08 |
| % MAF Fixed Carbon | 99.85 |
| % MAF Volatile | 0.15 |
| lb $SO_2$/mm Btu | 10.20 |
| lb Sulfur/mm Btu | 5.10 |

NQA ISO9002 REGISTERED COMPANY
Certificate No. 7061/1

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

Denver Laboratory

MEMBER ACIL

F-465

Original Watermarked For Your Protection

TERMS AND CONDITIONS ON REVERSE