JSF fly ash

# COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • TEL: 630-953-9300 FAX: 630-953-9306

SINCE 1908®

SGS Member of the SGS Group (Société Générale de Surveillance)

ADDRESS ALL CORRESPONDENCE TO:
4665 PARIS STREET
SUITE B-200
DENVER, CO 80239
TEL: (303) 373-4772
FAX: (303) 373-4791
www.comteco.com

May 30, 2002

TENNESSEE VALLEY AUTHORITY
1101 Market Street PSC 1A
Chattanooga TN 37402
RENEE B. MERRELL

SAMPLE No.: 257750
SAMPLE TYPE: DRY FLY ASH
REMARKS: FLY

Date Received March 5, 2002
Analysis report no. 72-470147

| PROXIMATE ANALYSIS | As Received | Dry Basis |
|---|---|---|
| % Moisture | 0.65 | xxxxxx |
| % Ash | 93.55 | 94.16 |
| % Volatile | < 0.01 | < 0.01 |
| % Fixed Carbon | 5.79 | 5.83 |
| | 100.00 | 100.00 |
| Btu/lb | 527 | 530 |
| % Sulfur | 0.12 | 0.12 |
| MAF Btu/lb | 9075 | |

| ULTIMATE ANALYSIS | As Received | Dry Basis |
|---|---|---|
| % Moisture | 0.65 | xxxxxx |
| % Carbon | 5.30 | 5.33 |
| % Hydrogen | 0.06 | 0.06 |
| % Nitrogen | 0.32 | 0.32 |
| % Sulfur | 0.12 | 0.12 |
| % Ash | 93.55 | 94.16 |
| % Oxygen | 0.00 | 0.01 |
| | 100.00 | 100.00 |

| ANALYSIS OF ASH | % Weight Ignited Basis |
|---|---|
| Silica, $SiO_2$ | 56.85 |
| Alumina, $Al_2O_3$ | 26.05 |
| Titania, $TiO_2$ | 1.16 |
| Ferric Oxide, $Fe_2O_3$ | 8.79 |
| Lime, CaO | 1.59 |
| Magnesia, MgO | 1.20 |
| Potassium Oxide, $K_2O$ | 3.27 |
| Sodium Oxide, $Na_2O$ | 0.34 |
| Sulfur Trioxide, $SO_3$ | 0.20 |
| Phosphorous Pentoxide, $P_2O_5$ | 0.18 |
| Strontium Oxide, SrO | 0.10 |
| Barium Oxide, BaO | 0.21 |
| Manganese Oxide, $Mn_3O_4$ | 0.06 |
| Undetermined | 0.00 |
| Alks. as $Na_2O$, Dry Coal Basis | 2.35 |
| Base:Acid Ratio | 0.18 |
| T250 Temperature | 2793 |

| | |
|---|---|
| Silica Value | 83.08 |
| Type of Ash | BITUMINOUS |
| Fouling Index | 0.06 |
| Slagging Index | 0.02 |
| % MAF Fixed Carbon | 99.83 |
| % MAF Volatile | 0.17 |
| lb $SO_2$/mm Btu | 4.55 |
| lb Sulfur/mm Btu | 2.28 |

NQA ISO9002 REGISTERED COMPANY
Certificate No. 7061/1

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

Denver Laboratory

MEMBER ACIL

F-465

Original Watermarked For Your Protection

TERMS AND CONDITIONS ON REVERSE